

STATE OF TEXAS WELL REPORT for Tracking #298253

Owner:	WAYNE MUELLER	Owner Well #:	No Data
Address:	17522 HAMILTON POOL RD. AUSTIN, TX 78738	Grid #:	57-48-5
Well Location:	17522 HAMILTON POOL RD. AUSTIN,, TX 78738	Latitude:	30° 17' 36" N
Well County:	Travis	Longitude:	098° 02' 50" W
		Elevation:	No Data
Type of Work:	New Well	Proposed Use:	Domestic

Drilling Start Date: **6/26/2012** Drilling End Date: **6/26/2012**

	Diameter (in.)	Top Depth (ft.)	Bottom Depth (ft.)
Borehole:	9	0	50
	6.5	50	740

Drilling Method: **Air Rotary**

Borehole Completion: **CASED**

	Top Depth (ft.)	Bottom Depth (ft.)	Description (number of sacks & material)
Annular Seal Data:	0	50	7 CEMENT
	0	50	4 VOLCLAY

Seal Method: **Slurry**

Distance to Property Line (ft.): **N/A**

Sealed By: **Driller**

Distance to Septic Field or other
concentrated contamination (ft.): **N/A**

Distance to Septic Tank (ft.): **No Data**

Method of Verification: **WELL DRILLED FIRST**

Surface Completion: **Surface Sleeve Installed**

Water Level: **447 ft. below land surface on 2012-06-26** Measurement Method: **Unknown**

Packers: **6 BURLAP, PVC 50',440',460',580',600',
620'**

Type of Pump: **Submersible**

Well Tests: **Jetted** Yield: **7-10 GPM**

Water Quality:

Strata Depth (ft.)	Water Type
40	TRINITY

Chemical Analysis Made: **No**Did the driller knowingly penetrate any strata which
contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **CENTEX PUMP & SUPPLY, INC.**
2520 HWY. 290 WEST
DRIPPING SPRINGS, TX 78620

Driller Name: **AARON GLASS**License Number: **4227**Comments: **No Data**

Lithology:
DESCRIPTION & COLOR OF FORMATION MATERIAL

Casing:
BLANK PIPE & WELL SCREEN DATA

From (ft)	To (ft)	Description
0-1		TOP SOIL
1-10		CALICHE
10-12		BLUE LIMESTONE
12-180		GRAY LIMESTONE
180-320		GRAY/TAN LIMESTONE
320-330		WHITE LIMESTONE
330-380		GRAY/TAN LIMESTONE
380-460		TAN/GRAY LIMESTONE
460-500		TAN LIMESTONE
500-550		GRAY LIMESTONE
550-560		GRAY LIMESTONE
		W/HAMMETT STRIPS
560-600		HAMMETT CLAY
600-610		HAMMETT CLAY W/RED CLAY
610-660		GRAY/TAN SAND
660-700		RED SANDSTONE
700-720		RED SAND W/GRAVEL
720-740		BLACK LIMESTONE

Dia. (in.)	New/Used	Type	Setting From/To (ft.)
5"	OD	N SDR17 PVC	+3 TO 740
5"	OD	N SDR17 PVC SLOT	660 TO 740 .032

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

**Texas Department of Licensing and Regulation
P.O. Box 12157
Austin, TX 78711
(512) 334-5540**